

If calling please ask for:

**Peter Spillane**

Telephone:

8204 3611

Reference:

Community Safety/16177/60091

12 November 2009

The Manager

Fire System Services

PO Box 16

PROSPECT SA 5082



**METROPOLITAN  
FIRE  
SERVICE  
SOUTH AUSTRALIA**

99 Wakefield Street  
Adelaide SA 5000

GPO BOX 98  
Adelaide SA 5001

Tel +61 8 8204 3600  
Fax +61 8 8204 3838

[www.samfs.sa.gov.au](http://www.samfs.sa.gov.au)

ABN 26 897 550 904

Dear Nick,

This Department acknowledges your correspondence regarding your application for recognition as a Fire Protection Contractor.

On the information presented, your company is accepted as an installer of thermal / smoke automatic fire alarms for connection to Fire Service equipment.

All fire detection and suppression components incorporated into any new or existing fire system connected to and monitored by the SAMFS must be listed in the CSIRO's ActivFire Scheme, Register of Fire Protection Equipment.

All systems are to be installed as per Australian Standard 1670, requirements of the current Building Regulations and any other relevant standards and/or codes.

The SAMFS Fire Safety Department reserves the right to seek confirmation of compliance with AS2118. from an independent organisation.

Please note that our copy of our 'Fire Alarm Conditions of Connection' which are to be complied with, can be down loaded from SAMFS's web site;

[www.samfs.sa.gov.au](http://www.samfs.sa.gov.au) / community policies/ commercial pages.



**Government  
of South Australia**