

TABLE 1.11(A)
ROUTINE SERVICE FREQUENCIES FOR EACH SECTION

AS 1851 Section		Monthly	Three-monthly	Six-monthly	Yearly	Five-yearly	Ten-yearly	Twenty-five-yearly	Thirty-yearly
2	Automatic fire sprinkler systems	✓		✓	✓	✓	✓	✓	✓
3	Fire pumpsets	✓		✓	✓	✓	✓		
4	Fire hydrant systems	✓*			✓	✓			
	Hydrant valves			✓	✓				
5	Water storage tanks for fire protection systems	✓		✓	✓		✓		
6	Fire detection and alarm systems	✓		✓	✓	✓			
7	Special hazard systems	✓		✓	✓		✓		
8	Delivery lay flat fire hose				✓				
9	Fire hose reels			✓	✓				
10	Portable and wheeled fire extinguishers			✓	✓	✓			
11	Fire blankets			✓					
12	Passive fire and smoke systems		✓**	✓	✓				
13	Fire and smoke control features of mechanical services	✓	✓	✓	✓	✓			
14	Emergency planning in facilities	✓		✓	✓				

*Where pumpsets are fitted.

**Where horizontal sliding doors are fitted.

NOTE: The responsible entity may elect to conduct monthly activities on a weekly frequency.

TABLE 1.11(B)
FREQUENCY TOLERANCES

Frequency	Tolerance (±)
Monthly	5 working days
Three-monthly	10 working days
Six-monthly	1 month
Yearly	2 months
Five-yearly	3 months
Ten-yearly	6 months
Twenty-five-yearly	6 months
Thirty-yearly	6 months

NOTE: The tolerance schedule is not intended to require additional routine service activities to be carried out (e.g. six monthly routines carried out at five or seven monthly intervals).